



Secondt Floor

(showing structure above)





Schedule NumberStructural OpeningLengthMember TypeIL1ID7840mm1200mmIG Box 100 or similar approved.

Roof

STRUCTURAL N	NOTES			
Please refer to a	ll other design drawings by others.	A1		
Please refer to drg. no. 1088/300 for specification and notes relating to structural engineering designs.				
Blockwork strengths to be as follows: -				
From top of foundation to u/s of 1st floor- $7.3$ N/mm²From 1st floor and above- $3.5$ or $5$ N/mm²				
STRUCTURAL KEY				
<u>←</u>	Span direction of infill members.			
MJ	Movement joint in brickwork only (movement jo blockwork by supplier).	ints in		
IL	Internal box lintels.			
EL	External cavity lintels.			
	7.3N/mm <sup>2</sup> strength blockwork.			
	3.5N/mm <sup>2</sup> or 5.0N/mm <sup>2</sup> strength blockwork.			
	Engineering brickwork.			
All lintels to be 1	IG lintels of similar approved. Lintel sizes to be co	nfirmed.		

R	Rev Amendment		Date
P1	First issue.	SWF	17.10.11
P2	Lintels added.	SWF	11.11.11
P3	Blockwork wall removed. Lintel removed. Girder truss added.	SWF	11.11.11
А	Issued as CONSTRUCTION issue.	SWF	13.12.11

